



# Enhancing the Energy Efficiency of Wastewater Aeration – Phase 2 (focus on Bartlett, TN, WWTP)

Charles McEntyre

Senior Environmental Engineer

Tennessee Valley Authority

Chattanooga, TN

- 5-10% of all electrical consumption in the United States is water and wastewater related
- Economic growth follows the sewer lines not the electric lines
- Community infrastructure concerns are increasingly important to business and industry

- People – 33%
- Electricity – 30 to 40 %
  - 80 % of electricity is used in pumps/motors (~ 25% of budget)
  - Lights
  - Building HVAC and ventilation
- Miscellaneous
  - Chemicals – 15 to 20 %
  - Telephone, Federal, Federal Insurance, Tax, etc.

- Typical systems use 1,300-2,400 kWH per million gallons treated
- Aeration equipment consumes almost half of this amount
- EPA and EPRI published guidelines in the mid-1990s on more efficient aeration systems

- Efficient automated aeration controls have reduced electricity demand for some facilities by 15-40%
- However, many small to mid-size systems manually control their aeration systems
- Manual controls are normally set to handle expected maximum daily loadings

- Help plants save energy and improve process stability
- Demonstrate the use of optical luminescent or fluorescent technology-equipped dissolved oxygen (DO) probes and variable speed drives (VSD) among small to mid-size wastewater utilities

- The WEF Manual of Practice No. FD-2, Energy Conservation in Wastewater Treatment Facilities (1997) contains the following range of values:
- Energy used per million gallons treated (279-928 kWh/MG)
- Percent of total plant energy used for secondary treatment only (29-48 %)

- Energy used per pound of BOD removed (0.4-2.6 kWh/lb BOD)
- Energy used per million gallons treated (508-2,428 kWh/MG)
- Oxygen transfer efficiency (2.6-83 %)
- Percent of total plant energy used for secondary treatment only (27-60 %)



# InsiteIG DO & ABB VSD Demo Facility



## Memphis Light, Gas & Water – City of Bartlett, TN

John Harris – MLGW; Jennifer Brogdon – TVA; and Larry Gamblin – City of Bartlett

- 2 Oxidation ditches
- Design capacity 2 MGD, current flow 1 MGD
- Each ditch has 3 rotor aerators, each driven by a 60 hp motor
- Operated 1 rotor in each ditch continuously and activated 2<sup>nd</sup> rotor during estimated peak flows with timers






- Electrical metering - TVA CSC & MLGW
  - 1-2 weeks prior to equipment installation
  - Allow process to stabilize for 2-4 weeks
  - 1-2 weeks after process stabilization
- Sample influent and effluent wastewater
- Determine relationship between the peak and daily wastewater loadings and the peak and daily electricity demand

# Bartlett Background

Bartlett Wastewater Plant - 5258 Shelter Run Lane, Bartlett  
480 Volt Pump Motors  
Demand Profile



- Added InsitelG dissolved oxygen system to provide continuous, accurate readings of dissolved oxygen in each ditch
- Added ABB variable speed drives to take the DO 4-20 milliamp signals and ramp one motor per ditch up and down to maintain an optimum DO level



Rick Davis, InsiteIG, and  
dissolved oxygen probe

InSiteIG DO control box





Bob Zurolo, ABB, and variable speed drives

Rick Davis & Larry Gamblin with PLC






- 1 rotor in each ditch ramped up and down by DO probe/VSD combination
- Plant never needed 2<sup>nd</sup> rotor in either ditch
- Reduced peak demand 39% from 130 kW to 79kW
- Reduced kWh 13% from 1,550 to 1,350 kWh/day

# Bartlett Demonstration

**Bartlett Wastewater Plant - 5258 Shelter Run Lane, Bartlett**  
**480 Volt Pump Motors**  
**Demand Profile**



- Original Control with Timers
  - 1553 kWh/day; cost/year = \$28,342
  - 130 kW; cost/year = \$14,227
- DO probes only
  - 1521 kWh/day; cost/year = \$27,758
  - 110 kW; cost/year = \$12,038
- DO probes + VFD's
  - 1356 kWh/day; cost/year = \$24,747
  - 79 kW; cost/year = \$8,646

- DO Probe system cost - \$3,500
- VFD's cost - \$10,000
- Total cost - \$13,500
- Yearly savings – Probes only = \$2,773
  - Payback = 1.26 years, save over \$10,000 in 5 years
- Yearly savings – Probes + VFD's = \$9,177
  - Payback = 1.47 years, save over \$32,000 in 5 years

## **Rick Davis, Insite IG**

- DO probes
- tel: (985)639-0006
- [rdavis@insiteig.com](mailto:rdavis@insiteig.com)
- <http://www.insiteig.com/>

## **Bob Zurolo, ABB**

- VSD
- tel: 704-560-3592
- [bob.zurolo@us.abb.com](mailto:bob.zurolo@us.abb.com)
- [www.abb-drives.com](http://www.abb-drives.com)



- “Best Practices” guide describing the state of the art for optical luminescent, or fluorescent DO probes
  - including performance, reliability, and costs (capital and O&M) data
- Screening tool to help assess a plant’s suitability for this technology



# Funding Partners

---

- Tennessee Valley Authority
  - Customer Resources
  - Research & Technology Applications
- American Public Power Association,  
Demonstration of Energy-Efficient Developments  
(DEED) Program



- Contacts:

- Leanne Whitehead – (931) 619-0014,  
[lawwhiteh@tva.gov](mailto:lawwhiteh@tva.gov)
- Charlie McEntyre – (423) 751-4123,  
[clmcentyre@tva.gov](mailto:clmcentyre@tva.gov)
- Jennifer Brogdon – (423) 751-8397  
[jnbrogdon@tva.gov](mailto:jnbrogdon@tva.gov)